

ADDENDUM NO. 2

CIP T-21/T-129 SCIOTO DARBY ROAD AND LEPPERT ROAD IMPROVEMENTS

CITY OF HILLIARD
DEPARTMENT OF PUBLIC SERVICE/DIVISION OF ENGINEERING
3800 MUNICIPAL WAY
HILLIARD, OHIO 43026

ADDENDUM No. 2 – DATE: October 20, 2017

To All Bidders:

This Addendum amends or supplements the original specifications and related documents for this project. Please include a copy of this Addendum with your bid submission to prove receipt of the Addendum and its terms.

1. General Notes – Add the following:

- A. Item 259 – Permanent Pavement Replacement, Type 1 – Bituminous. Utility trenches (water, sewer, and underdrain outlets) that cut through existing asphalt pavements to be milled and overlaid shall be repaired in accordance with Item 259 for Type 1 – Bituminous, and paid at the unit price bid per square yard.
- B. Straight Curb with Underdrain. The cost of No. 57 aggregate base associated with straight curb that has underdrain shall be included in the unit price bid per lineal foot for “Item 609 – 18 ½” (or 17 ¼”) Straight Concrete Curb w/Underdrain (Including No. 57 Aggregate Base)” per the typical sections and the detail on Sheet 31. Only straight curb with underdrain and concrete curb and gutter have No. 57 aggregate base. All other straight curb (without underdrain) sits on Item 304 aggregate base.
- C. Item 305 – Concrete Base (18 ¾” or 17 ¾” Thickness). This item covers concrete base used where proposed curb or curb and gutter are placed within existing pavement to be milled and overlaid per the typical sections and Detail “B” on Sheet 20, Detail “C” on Sheet 26, and Detail “D” on Sheet 28.
- D. Roundabout Walls. The roundabout walls detailed on Sheet 281 will be paid at the unit price bid per lineal foot for “Item Special – Roundabout Walls”, and shall include all excavation, labor, material, and backfill, as detailed for a complete wall.

2. Appendix A: Bid Schedule

Replace "Appendix A: Bid Schedule" in the bid book with the revised PDF file provided as part of this addendum. The revised Appendix A: Bid Schedule is also provided as a protected Excel spreadsheet for use by bidders. An unprotected Excel spreadsheet will not be provided.

3. Appendix D: Detailed Construction Drawings

A. Replace the following plan sheets with the revised plan sheets provided as part of this Addendum:

- Sheets 3, 5, 6, 7 and 9 (General Notes)
- Sheets 10 and 11 (General Summary)
- Sheets 20, 21, 23, 26, 27, 29-31, 33, and 34 (Typical Sections)
- Sheets 36, 37, and 40-43 (Plan and Profile)
- Sheets 125-129 (Water)
- Sheet 143 and 163 (Lighting)
- Sheet 279 and 279A (Landscape)

B. Add the following Standard Drawings:

- City of Columbus: L-9002E
- ODOT: RM-1.1

This Addendum shall be considered in submitting your bid and shall be attached to Appendix A - Bid Schedule and made a part thereof. Please sign and date below and include as part of your bid submittal to acknowledge receipt of Addendum No. 2.

Please direct any questions regarding this process to Clyde Seidle, Director of Public Service at cseidle@hilliardohio.gov.

Clyde R. Seidle, P.E.
Director of Public Service

Signature of Bidder

Date

Company Name